


Office of the Executive Engineer
P. H. Division, Muzaffarpur

Letter No. :1062...../


Dated : 16-05-2023,

CERTIFICATE


This is to certify that "SRT SCHOOL" (Under Bihar Technical Education Trust, Motihari) Boddh Vihar, Rautania, P.O. - Mansurpur - Chamarua, Muzaffarpur - 843113 (Bihar) is having adequate safe drinking water and sanitation facility.


16/05/23

Executive Engineer,
P. H. Division, Muzaffarpur


Chemist
16/05/23

कारगपानक अभियता
लोक स्वास्थ्य प्रमंडल
मुजफ्फरपुर


Principal
SRT School
Boddh Vihar Rautaniya, Muz.
Aff No-330211
School No-65220

PUBLIC HEALTH ENGINEERING DEPARTMENT

Water Quality Test Report

Division Name :- P. H. Division, Muzaaffarpur.

District Name : Muzaaffarpur

Month : May 2023

Name of the School :- S R T SCHOOL


Sl. No.	Testing Date	Block	Panchayat	Village	Habitation / Ward	Location of Source	pH	Turb. Cond.	TDS	TH	Ca	Mg	Cl	Alk	Fe	No ₃	So ₄	F	As	Total Cell	Remarks	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1	11.05.2023	Marwan	Makdumpur Kodaria	Rautania	-	Near Boddh Vihar, Mansurpur, Chamanua, Muzaaffarpur - 843113 (Bihar)	6.62	0.2	103.08	25.2	8.3	2.2	12.6	27.4	BDL	BDL	BDL	BDL	-	-	-	-
							Desirable Limit **	6.5-8.5	-	500	200	75	30	250	200	0.3	45	200	1.0	##	-	-
							Permissible Limit* in absence source (IS 10500-2012 - 2nd Revision	NR	5.0	2000	600	200	100	1000	600	1	NR	400	1.5	NR	-	-


Note: (1) Drinking Water Specification First Revision -IS:10500:2012, Edition 2.2(2003-09,12,20)(Reaffirmed1993), (2) BDL = Below Detection Limit, (3)NR = No Relaxation, (4) ND = Not Done.

(a) Throughout any year, 95% of the samples should not contain coliform organisms in 100ml, (b) No sample should contain more than 10 coliform organisms per 100ml,

(c) Coliform organisms should not be detected in 100ml of any two consecutive samples.

Copy forwarded for information to: (i) Consultant Water Quality Cell, PHED, Govt. of Bihar, (ii) Director, Water Quality Cell, PHED, Govt. of Bihar, (iii) SLWTL, PHED, Govt. of Bihar.


 Principal
 SRT School
 odh Vihar Rautania, Muz.
 Aif No-330211
 School No-65220


 Chemist
 R. W. T. L., Muzaaffarpur